

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1220404

Product: Float switch

Type: FS1, FS2

Rating: 48 V, 2 A DC, 4 A AC, IP 68 (FS1), 230 V, 2 A DC, 5 A AC, IP 68 (FS2)

Ordering firm: ALUMO, s.r.o.
Za Nádražím 2695, 397 01 Písek, Czech Republic

Manufacturer: ALUMO, s.r.o.
Za Nádražím 2695, 397 01 Písek, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 302028-01/01 of: 09.07.2013

A sample of the product was found to be in conformity with:
ČSN EN 60730-1 ed. 2:01, ČSN EN 60730-2-15 ed. 3:19 cl. 5, 6, 7, 8, 9, 10, 11, 12, 13, 20, 21

Other data:

The validity of the certificate is limited to: 15.08.2025

16.08.2022

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



221634-01